



NOTES:

1. All clearances to be in conformance to the most stringent requirements of either the NESC, NEC or other codes of governmental or regulating authorities as applicable.
2. If length of conduit exceeds 10 feet, coupling is permitted an end adjacent to meter.
3. Entrance location should always be spotted by Sumter EMC prior to installation.
4. This drawing shows Sumter EMC requirements only; check with your local code office for county or city codes, if required, prior to installation.
5. Consult with a licensed electrician for conformance to the National Electrical Code (NEC) and local codes, and for proper sizing and installation of conductors and equipment.
6. Electrical inspections are required after wiring is completed in Marion, Lee, and Sumter counties before meter is set. Other counties or municipalities may require permits - contact your local government authorities to verify permit requirements.

**SUNTER
EMC**

MAST TYPE SERVICE ASSEMBLY GUIDE

DATE: 02-13-02

K4.2G